



**NOTES:**

Dimensions shall be varied as directed to suit make of valve furnished.

Width shall be as required to allow access to bolts. (6" min.)

When installing horizontal gate valves, the operator shall be set on either the south or east side of the proposed water main.

L-6617.Dwg Revision Date: 1/2/13

CITY OF COLUMBUS  
DEPARTMENT OF PUBLIC UTILITIES  
DIVISION OF WATER

APPROVED: *R.C. Westerfield* 5-16-13  
ADMINISTRATOR DATE

STANDARD DETAIL  
CONCRETE VALVE SUPPORT  
FOR HORIZONTAL  
GATE TAPPING VALVE w/BY-PASS

